



February 7th, 2020

RE: Stevensville Schools Main Gym Floor Replacement – Public Bid

ADDENDUM #1

The following amends the original Bid Package. Acknowledge receipt of this Addendum #1 in your response. Failure to acknowledge receipt of this Addendum #1 may result in disqualification of your response.

Item #1: (substitutions)

- A. Owner is accepting a gym floor overlay system as an acceptable bid option. Bidder to include a complete gym floor system with same finish and performance requirements as provided in the bid package as well as any/all ramping or additional thresholds. This alternate bid option to include re-securing via fasteners of (45) “dead spots” in the existing floor assembly where the plywood substrate is not resting securely atop the existing structural beams. Your bid MUST be on the bid form included in this addendum. Owner reserve the right to select the low/responsible bid for either option.

Item #2: (additional information)

- A. Inspection of the crawl space under the gym floor on 2/3/2020 revealed there is no vapor barrier present; however, there is no visible evidence of any issues from ground water or humidity. That being said, bidders are to include furnish & install of a new vapor barrier below the new floor assembly in their bids. Vapor Barrier to be a minimum 6 mil poly with 6” laps or taped joints.
- B. There were (9) existing volleyball standards counted in the existing court so bidder shall include furnish and install of (9) new volleyball standards and court lines as similar to what exists now.
- C. The existing joists are manufactured joists and about 20” OC and look to be in great condition.
- D. The existing open-air grills at the north end of the gymnasium will need to be salvaged and reinstalled/secured into the new gym floor assembly.

Item#3: (spec changes)

- A. 024119-Selective Demolition. Paragraph 3.4.B: Delete paragraph in its entirety and replace with:
 - a. “no temporary shoring is not anticipated to be required based upon visible inspection of the gym floor and conditions beneath the floor. However, gym floor replacement contractor is responsible for not damaging the existing floor structure and should notify the Owner immediately and stop work should there be any concern of an unsafe condition.”

Item#4: (bid date)

- A. The bid due date is being extended from 2/10/2020 to 2/24/2020, with sealed bids due no later than 3:00pm.

END OF ADDENDUM #1

**STEVENSVILLE SCHOOLS MAIN GYM FLOOR REPLACEMENT
BID FORM**

BIDDING CONTRACTOR: _____

PROJECT NAME: MAIN GYM FLOOR REPLACEMENT

BID:

THE UNDERSIGNED BIDDER, HAVING CAREFULLY EXAMINED THE FULL BID PACKAGE AND ANY/ALL ADDENDUMS AND BEING FAMILIAR WITH THE ON-SITE CONDITIONS HEREBY AGREES TO FURNISH ALL MATERIAL, LABOR, EQUIPMENT, SERVICES, SUBMITTALS, MAINTENANCE DOCUMENTS AND WARRANTIES AS NECESSARY TO COMPLETE THE WORK FOR EITHER OPTION IN THE TIMEFRAME AS DESCRIBED IN THE BID DOCUMENTS FOR THE STIPULATED SUM OF:

**BID OPTION#1, AS DESCRIBED IN BASE BID SPECIFICATIONS, GENERALLY DESCRIBED AS THE
"FULL GYM FLOOR REPLACEMENT OPTION":**

_____ Dollars (\$ _____)
(bid amount written in words above)

**BID OPTION#2, AS DESCRIBED IN ADDENDUM #1, GENERALLY DESCRIBED AS THE
"DIRECT OVERLAY OPTION:**

_____ Dollars (\$ _____)
(bid amount written in words above)

BIDDER ACKNOWLEDGES ADDENDUM #1 DATED _____

SUBMISSION OF BID:

Respectfully submitted this _____ day of _____, 2020.

Submitted by _____ (Name of Bidding Firm or Corporation)

Authorized Signature _____ (Handwritten/ink signature)

Signed by _____ (typed/printed name as signed above)

Title _____

Street Address _____

City, State, Zip _____ Phone _____

E-Mail _____

End of Bid Form